

## ADDENDUM #2

---

<i>Client</i>	Wallowa Health Care District	<i>Date</i>	March 5, 2019
<i>Project</i>	Wallowa MOB Addition	<i>Project #</i>	18038

---

**GENERAL INFORMATION:**

The following changes, additions and deletions to the Contract Documents dated January 25, 2019, hereby become part of the Contract Documents.

This Addendum has 1 sheet.

**ADDENDUM ITEMS:**

General:

---

<i>Item</i>	<i>Reference</i>	<i>Description</i>
Item 1	Clarification	Electric ceiling radiant panels to be controlled by a stand-alone locally adjustable thermostat. They are not to be added to the building automation system

**SPECIFICATIONS:**

---

<i>Item</i>	<i>Section</i>	<i>Description</i>
Item 1	23 0923_DDC Controls	1.04-A: Delete "Northwest Controls Co." and replace with "Johnson Controls local branch office"
Item 2	23 0923_DDC Controls	1.04-H: This paragraph does not refer to a specific Johnson Controls product and uses the term Metasys user interface as generic. New spaces and equipment shall be added to the existing user interface using the same style graphics as currently exist in the facility. No re-work of existing facility graphics is required
Item 3	23 0923_DDC Controls	1.05-E-3: Delete "Five (5) non-warranty emergency service calls shall be provided free of charge per year".

**DRAWINGS:**

---

<i>Item</i>	<i>Reference</i>	<i>Description</i>
Item 1	WALL MOUNTED FAN-COIL UNITS SCHEDULE	New schedule added to documents.

---

End of Addendum

Attachments:

WALL MOUNTED FAN-COIL UNITS SCHEDULE.PDF